



OIL TANK QUESTIONNAIRE

Policy Number:		Insured:	
Broker:		Date:	

INSTALLATION

Address of installation: _____

Location of tank: Exterior above ground Exterior in-ground Interior above ground Interior in-ground

Is the tank located on a level concrete platform or floor? Yes No

Is the tank within 1.5metres (5feet) of a heat source? Yes No

Is there a clear space of at least 60cms (24ins) from all exposed sides? Yes No

Is the vent pipe at least 15cms (6ins) higher than the fill pipe? Yes No

Is the fuel line protected? Yes No Describe: _____

For Exterior Installations

What is the distance from the tank to the house? _____

Is the tank protected from vehicle impact? Yes No

Is the tank supported against shifting? Yes No

Is there a loop in supply line just before the tank connection? Yes No

Note: A loop is required to allow movement due to frost to prevent the line from becoming stretched or severed.

TANK

Age: _____ Year Installed: _____ Capacity: _____

Was the tank professionally installed? Yes No

Is the tank labeled? ULC CSA Other _____ None

Has the tank been painted with a rust proof paint? Yes No

Are there any signs of leakage/spillage? Yes No

Are there fumes or odours evident? Yes No

Has the tank been inspected in accordance with provincial regulations?* Yes No

*please provide a copy of the most recent inspection report where applicable.

GENERAL

Is the tank filled all year round? Yes No

Are there any empty tanks on the property? Yes No

Please describe any prior losses or problems related to the oil tank or its installation.

Broker Signature _____

PLEASE REFER TO COMPANY GUIDELINES AS A PHOTOGRAPH OF THE TANK MAY BE REQUIRED.